



Customer Name: **GOING UNITED ACTOUM CHURCH.**
 Site Address: **BAMINGTON ROAD, GOING BY SEA WOVNING, WEST SUSSEX.**
 Postcode: **BN12 4EA**

| | | |
|--------------|---------------------|--|
| Type of Work | Planned Maintenance | <input checked="" type="checkbox"/> Takeover Service |
| Call out | Modification | Repair |
| Quoted | Installation | False Alarm |
| Daywork | Commission: | Other |

Site Reference Number: **M 4293**
 Customer Order Number: **SLA**

Date of Last Service Visit: **MARCH 24** Next Service Visit Due: **MARCH 2**
 Is this the last Routine Inspection within a 12 Month Contract Period? Yes No

Equipment: Fire Alarm Disabled Refuge Other:

System Category: **7** BAFE Certificate of Compliance No. N/A

Applicable to BAFE SP203-1 Maintenance Certification: BAFE Reg. No. 101799

Type of System & Standards / Code of Practices: **A** Type of Signalling: **A**

False Alarm Details:

| | | | |
|--|-------------|--------------------|-------------------------------------|
| Cause of False Alarm | | | |
| Equipment fault | Unwanted | Transmission Fault | |
| Malicious | Good Intent | Cause not Known | |
| Did Brigade Attend: | Yes | No | |
| No. of false alarms since last Service visit * | | 0 | |
| No. of false alarms over last 12 months | | | |
| No. of false alarms per 100 automatic fire detectors per annum | | | |
| Is further action required? | Yes | No | <input checked="" type="checkbox"/> |

Tests/checks and inspections carried out in accordance with BS 5839-1

Sub clause 45.3 – Periodic Inspection and Test (*)

| | | | |
|-----------------------------------|-------------------------------------|---------------------------------------|-------------------------------------|
| Log book checked & updated * | <input checked="" type="checkbox"/> | O&M docs. Certs. & drawings seen * | <input checked="" type="checkbox"/> |
| Survey for change of layout/use * | <input checked="" type="checkbox"/> | Control & Indicating Equip checked * | <input checked="" type="checkbox"/> |
| Link to ARC/Brigade checked * | N/A | Detection is free from obstructions * | <input checked="" type="checkbox"/> |

Sub clause 45.5 – Inspection and Test over a 12 Month period (#)

| | | | |
|----------------------------------|---|------------------------------------|-------------------------------------|
| Cause & Effects Tested # | <input checked="" type="checkbox"/> | Alarm / warning devices tested * # | <input checked="" type="checkbox"/> |
| Cables & Fixings inspected # | <input checked="" type="checkbox"/> | Analogue levels checked # | <input checked="" type="checkbox"/> |
| Detectors & Call Points Tested # | 25% <input type="checkbox"/> 50% <input checked="" type="checkbox"/> 75% <input type="checkbox"/> 100% <input type="checkbox"/> | | |

Power Supplies Checked * Charge volts: **13.2** Volts
 Standby battery load tested # Standby Period: **-** Hrs

Battery volts: **13.0** Volts Battery size fitted: **1x12V34** Ah
 Quiescent load: **-** Amps Alarm load: **-** Amp

Description of Work Carried Out / Engineer's Report:

CARRIED OUT A 50% SERVICE OF THE FIRE ALARM SYSTEM. SEE TEST SCHEDULES FOR DEVICES TESTED AT THIS VISIT. NO FAULTS FOUND. SYSTEM LEFT IN WORKING CONDITION.

**2x LOW BATTERIES CALPOINTS (2x Q670 REQUIRED)
 SME REQUIRED QUOTE FOR BLANKET CHANGE OF BATTERIES**

Variations from the recommendations of clause 45 of BS 5839-1 for periodic or annual inspection and test (for Fire Alarm Maintenance visits only):

Materials Used:

| QTY | Make | Model | Description | QTY | Make | Model | Description |
|-----|------|-------|-------------|-----|------|-------|-------------|
| | | | | | | | |

Labour:

| Engineer's Name | Arrive | Depart | Travel Time | Total Hours |
|-----------------|--------|--------|-------------|-------------|
| | | | + | |
| | | | + | |

We, being currently a BSI Certified Company in respect of Fire Detection and Alarm Systems of the type(s) we have identified above (only applicable if completed) certify that the maintenance work detailed above complies with the Standard and / or Code of Practice identified and with all other requirements of the BAFE SP203-1 Scheme in respect of such a system. YES NO N/A

Where applicable to the work carried out above, I/We being the competent person(s) responsible for the servicing of the system(s) described above certify that the work complies to the best of my/our knowledge and belief with the recommendations of clause 45 of BS 5839-1 for periodic inspection and test/inspection and test over a 12 month period, except for the variations if any stated in this certificate. For and on behalf of Crays Fire:

Engineer's Sig: Print: **DANNY MANSSELLWOOD** Date: **01/11/2024**

I have denied permission for the alarm sounders / outputs to be tested as required by the above standard: YES NO N/A

I confirm that the above works have been carried out to my satisfaction and accept responsibility for the system including defects that have been brought to my attention as or on behalf of the nominated Responsible Person:

Customer's Sig: Print: **E SWIERK.** Date: **1.11.24**