

GURCO001

Portable Appliance Inspection and Test Record

COMPANY NAME & SITE ADDRESS:

Goring United Reformed Church, Barrington Rd, BN12 4EA.

CONTRACTOR'S DETAILS

Keith Best Electrical Contractors Ltd.

TEST EQUIPMENT:

Make, Model and Serial Number

TIS Autopat

COMPETENT PERSON

NAME (BLOCK CAPITALS)

Darren Brooks

(SIGNATURE)

DB

Site	Appliance Description	Appliance No.	VISUAL CHECKS					ELECTRICAL TESTS							Comments	Date of Test	Pass (P) or Fail (F)	
			Class (I, II, etc)	Fuse Rating (A)	Pass / Fail (✓) (X)			Earth Bond		Insulation		Functional / Load Test						
					Plug	Lead	Casing	Test Current (A)	Resistance (Ω)	MΩ	kA	Leakage	Sub Leakage					
Main Hall	Mixer	1	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	31/10/23	P
Main Hall	Feed back destroyer Pro	2	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	MP3 Recorder	3	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Tape deck	4	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	cd/DVD Player	5	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	LOOP AMP	6	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	AMP 1	7	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	AMP 2	8	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	PC Tower	9	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Monitor	10	IT	5	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Monitor	11	IT	5	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Monitor	12	IT	5	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Extension lead	13	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	TV	14	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	TV	15	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	TV	16	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	✓	"	P

GURCO001

Portable Appliance Inspection and Test Record

COMPANY NAME & SITE ADDRESS:

Goring United Reformed Church, Barrington Rd, BN12 4EA

CONTRACTOR'S DETAILS

Keith Best Electrical Contractors Ltd.

TEST EQUIPMENT:
Make, Model and Serial Number

TIS Autopart

COMPETENT PERSON

NAME (BLOCK CAPITALS)
Darren Brooks

(SIGNATURE)

DB.

Site	Appliance Description	Appliance No.	VISUAL CHECKS					ELECTRICAL TESTS						Comments	Date of Test	Pass (P) or Fail (F)
			Class (I, II, etc)	Fuse Rating (A)	Pass / Fail (✓) (X)			Earth Bond		Insulation MΩ	Functional / Load Test					
					Plug	Lead	Casing	Test Current (A)	Resistance (Ω)		kA	Leakage	Sub Leakage			
Main Hall	TV	17	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	31/10/23	P
Cornual Room	DVD Player	18	IT	15A	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Cornual Room	Mike AMP	19	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Cornual Room	cd deck	20	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Cornual Room	AMP	21	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Cornual Room	ext Lead	22	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Cornual Room	TV	23	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Cornual Room	Kettle	24	I	13	✓	✓	✓	N/A	✓	✓	✓	✓	✓	✓	-	P
Cornual Room	Kettle	25	I	13	✓	✓	✓	N/A	✓	✓	✓	✓	✓	✓	-	P
Cornual Room	Hoover	26	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Office	Copier	27	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Office	Shedder	28	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Office	Phone	29	II	600ma	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Office	Extension lead	30	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Office	PC tower	31	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P
Office	Electric heater	32	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	-	P

Portable Appliance Inspection and Test Record

REPORT NO.

GURCO01

COMPANY NAME & SITE ADDRESS: Boring United Reformed Church, Barrington Rd, BN12 4EA.

CONTRACTOR'S DETAILS: Neil Best Electrical Contractors Ltd.

TEST EQUIPMENT: Make, Model and Serial Number: TIS Autopat. COMPETENT PERSON: Warren Brooks NAME (BLOCK CAPITALS): Warren Brooks (SIGNATURE): WB

Site	Appliance Description	Appliance No.	VISUAL CHECKS					ELECTRICAL TESTS						Comments	Date of Test	Pass (P) or Fail (F)	
			Class (I, II, etc)	Fuse Rating (A)	Pass / Fail (✓) (X)			Earth Bond		Insulation		Functional / Load Test					
					Plug	Lead	Casing	Test Current (A)	Resistance (Ω)	MΩ	kA	Leakage	Sub Leakage				
Office	Dehumidifier	33	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	31/10/23	P
Office	Monitor	34	IT	5	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Office	Monitor	35	IT	5	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Office	Extension lead	36	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Kitchen	Microwave	37	IT	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Kitchen	Fridge	38	I	13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	"	P
Kitchen	Freezer	39	I	13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	"	P
Kitchen	Fridge-Freezer	40	I	13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Coffee Maker	41	I	13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Extension lead	42	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Kettle	43	I	13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	"	P
Main Hall	Wifi adapter Modem	44	II	1.5	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Main Hall	CCTV camera	45	IT	1	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P
Office	Extension lead	46	II	13	✓	✓	✓	N/A	N/A	✓	✓	✓	✓	✓	✓	"	P